ACCEPTED FOR PROCESSING - 2021 April 30 12:14 PM - SCPSC - 2019-224-E - Page 1 of 1

Table 2. Average Unit Capacity Factors During Operational Years (Duke Screening Study)[11]

Coal Facility	Area	Capacity (Summer MW)	Average Capacity Factor
Mayo 1	DEP	727	2.6%
Allen 2	DEC	162	3.4%
Allen 5	DEC	259	3.7%
Allen 1	DEC	162	3.8%
Allen 4	DEC	257	4.5%
Allen 3	DEC	258	6.0%
Roxboro 3	DEP	691	6.6%
Roxboro 1	DEP	379	7.7%
Roxboro 4	DEP	698	7.8%
Marshall 1	DEC	370	8.1%
Marshall 2	DEC	370	8.4%
Cliffside 5	DEC	544	12.0%
Roxboro 2	DEP	665	14.3%
Marshall 3	DEC	658	22.0%
Belews Creek 2	DEC	1,110	24.8%
Marshall 4	DEC	660	29.0%
Belews Creek 1	DEC	1,110	30.5%
Cliffside 6	DEC	844	N/A