ACCEPTED FOR PROCESSING - 2021 April 29 1:40 PM - SCPSC - 2019-225-E - Page 1 of 1

Table 2. Average Unit Capacity Factors During Operational Years (Duke Screening Study)

Coal	Facility	Area	Capacity (Summer MW)	Average Capacity Factor	1/2/2018 - 1/8/2018 Capacity Factor
Mayo		DEP	727	2.60%	95%
Allen	2	DEC	162	3.40%	60%
Allen	5	DEC	259	3.70%	72%
Allen	1	DEC	162	3.80%	82%
Allen	4	DEC	257	4.50%	87%
Allen	3	DEC	258	6.00%	67%
Roxboro	3	DEP	691	6.60%	94%
Roxboro	1	DEP	379	7.70%	100%
Roxboro	4	DEP	698	7.80%	99%
Marshall	1	DEC	370	8.10%	96%
Marshall	2	DEC	370	8.40%	95%
Cliffside	5	DEC	544	12.00%	95%
Roxboro	2	DEP	665	14.30%	93%
Marshall	3	DEC	658	22.00%	68%
Belews Creek	2	DEC	1,110	24.80%	100%
Marshall	4	DEC	660	29.00%	100%
Belews Creek	1	DEC	1,110	30.50%	99%
Cliffside	6	DEC	844	N/A	93%